

ADDENDUM #5



**Window Replacements at:
Short Beach Recreation Building**

1 Dorne Drive
Stratford, CT

TOWN PROJECT NUMBER: 2011-002

ISSUED FOR BID: 2/2/2011

PROJECT TEAM

Architects

THE GEDDIS PARTNERSHIP

71 Old Post Road-Suite 101

P.O. Box 1020

Southport, CT 06890

Phone: (203) 256-8700

Fax: (203) 255-0004

The work shall be carried out in accordance with the following supplemental instructions and in accordance with the Contract Documents.

MISCELLANEOUS CHANGES & CLARIFICATIONS

REQUESTS FOR INFORMATION (RFI's)

See attached RFI Log which addresses all RFI's to date.

END OF ADDENDUM NO. 5

| RFI LOG | | | | | |
|---|--|---------------|-------------|--|---------------|
| SHORT BEACH RECREATION BUILDING - WINDOW REPLACEMENTS | | | | | |
| Date: 2/2/2011 | | | | | |
| The Geddis Partnership Architects | | | | | |
| | Question | Date Received | Directed To | Response | Response Date |
| 1 | Are the U-factor & SHGC numbers a not to exceed number? | 1/20/2011 | Geddis | The specified U-factor, and SHGC values are not to exceed values. | 1/25/2011 |
| 2 | Alternate #2 Fiberglass - No one makes large awning windows. This would effect type I & J units. Would you then have these units fixed, or would you want double-hung or slide-by units? | 1/20/2011 | Geddis | Spec section 01230-3.1, Alternate #2, states: "Provide fiberglass windows in lieu of aluminum-clad windows. Type I and J windows shall remain fixed type." Under Alternate 2, fiberglass windows, states that type I and J windows shall be fixed type and not awning. | 1/25/2011 |
| 3 | The spec states that vendor shall be FSC accredited. Is FSC Certification intended? | 1/25/2011 | Geddis | FSC certification is not required for this project. Refer to Addendum #3. | 1/28/2011 |
| 4 | Fiberglass window manufacturer states that muntin patterns shown in window types I & J (Alternate 2 only) are not feasible. Please advise. | 1/25/2011 | Geddis | Window Types I & J for the Basebid and Alternate #2 shall both be aluminum-clad wood windows. | 1/28/2011 |
| 5 | The Ultrex fiberglass product only comes with a white interior. Do you want a price on that, or the Infinity product which can accommodate another interior color? | 1/28/2011 | Geddis | Provide All-Ultrex single-hung windows by Integrity as specified. | 1/28/2011 |
| 6 | The U value on the Marvin wood product is not 0.30, is that acceptable? | 1/28/2011 | Geddis | U-value of specified unit is acceptable. | 1/28/2011 |
| 7 | Do you want spacer bars between the glass on the Wood product? If not, please let us know because that changes the price by up to \$50 per window or more! | 1/28/2011 | Geddis | Spec calls out for muntins to be located between insulating-glass lites, not simulated divided lites. | 1/28/2011 |
| 8 | Do you require a Kynar finish? | 1/31/2011 | Geddis | Refer to spec section 08550-2.3-B-1 for specified aluminum finish. | 1/31/2011 |
| 9 | The drawings call out for interior trim to match existing, and the spec section 06202-2.2-B-1 calls out for white oak. Which wood trim is intended. | 2/1/2011 | Geddis | The intent is to match the existing trim. | 2/2/2011 |
| | | | | | |
| | | | | | |
| | | | | | |